AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE  J		PAGES 4
2. AMENDMENT/MODIFICATION NO.	3. EFFECTIVE DATE	4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT	NO.(Ifapplicat	
0001	24-Sep-2011	MIPROHRF2N0041J				
6. ISSUED BY CODE	W5J9JE	7. ADMINISTERED BY (Ifother than item 6)	CO	DE DE		
AFGHANISTAN DISTRICT NORTH (AEN) US ARMY CORPS OF ENGINEERS OPERATION ENDURING FREEDOM APO AE 09356		See Item 6				
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)			x 9A. AMENDM W5J9JE-11-R-	9A. AMENDMENT OF SOLICITATION NO. W5J9JE-11-R-0122		
8			9B. DATED (S 11-Sep-2011	EE ITEM 1	1)	
			10A. MOD. OF	CONTRAC	CT/ORDER N	4O.
	F. GIL 1991 GO	D.F.	10B. DATED	(SEE ITEM	I 13)	
CODE FACILITY CODE  11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS						
X The above numbered solicitation is amended as set fort				χ is not exte	ended.	
Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods:  (a) By completing Items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegramor letter, provided each telegramor letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.						
12. ACCOUNTING AND APPROPRIATION DA	ATA (If required)					
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS.  IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.						
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.						
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).						
C. THIS SUPPLEMENT AL AGREEMENT IS	SENTERED INTO P	URSUANT TO AUTHORITY OF:				
D. OTHER (Specify type of modification and authority)						
E. IMPORTANT: Contractor is not, is required to sign this document and return copies to the issuing office.						
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)  The purpose of this amendment is to make changes/corrections to the solicitation which include (1) provide responses to questions, (2) provide revised Appendix A-1 to this procurement. The proposal submission date remains unchanged, 3:00 p.m. local time on 11 October 2011.						
	ocument referenced in Iter	m9A or 10A, as heretofore changed, remains unchan	ged and in full force an	d effect.		
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.  15A. NAME AND TITLE OF SIGNER (Type or print)  16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)						
2 55 SECOND 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	W 000	TEL:	EMAIL			
15B. CONTRACTOR/OFFEROR	15C. DATE SIGN	ED 16B. UNITED STATES OF AMER	ICA	16	6C. DATE SI	GNED
	_	BY		2	24-Sep-2011	l <sup>®</sup>
(Signature of person authorized to sign)		(Signature of Contracting Off	icer)			

## SECTION SF 30 BLOCK 14 CONTINUATION PAGE

## SUMMARY OF CHANGES

SECTION SF 30 - BLOCK 14 CONTINUATION PAGE

The following have been added by full text:

AMENDMENT 0001 - SUMMARY OF CHANGES FOR Section 00010 - Solicitation Contract Form: Changes are bolded and underlined.

1. Page 3, number 2 under NOTES in the solicitation is changed to read:

From: All appendices and drawings applicable to this procurement are available on the following FTP website: ftp://ftp.usace.army.mil/pub/aed/.

To: All appendices and drawings applicable to this procurement are available on the following AED website: http://www.aed.usace.army.mil/.

- 2. Last date to submit questions is 1 October, 2011.
- 3. Questions and Responses

Question 1. It is stated in the drawing C-2 that sniper screening and concertina are optional for perimeter wall. Please state in which item should these prices be included in the price proposal?

Response: The contractor shall not include sniper screening. Concertina wire is a part of the normal perimeter wall and should be considered part of the proposal.

Question 2. Is there a construction period for one Project?

Response: Construction period is 400 days.

Question 3. Drawing XE-1 electrical site plan is contradicting with the concept site plan. Please clarify.

Response: Site plans are conceptual only. Each project will be unique and require the contractor to develop the master site plan including the layout of all utilities. Contractor shall assume that the site plan is correct for the sample project.

Question 4. In electrical drawing D E-1, it is shown only 1 generator and no backup generator is shown. Please kindly reconsider the number and the capacity of the generator(s). Please kindly state the volume of the fuel tanks and/or the time duration that the tanks to feed the generators?

Response: Section 01010 provides guidance on these issues and takes precedence over the drawings. Only one generator is required. Fuel storage is required for 30 days.

Question 5. Could you please kindly clarify that what the meaning of JOOH is? JOOH is mentioned on Price Proposal Schedule of subjected project.

Response: Job Office Overhead. JOOH costs are those costs at the project site that occur specifically as a result of the particular project

QUESTION 6 - The GATE HOUSE shown in sheet (C-101 of Appendix-B2) is not mentioned neither in SCOPE of WORK (section-0010) nor in Technical Specification (section 0015), please verify if it is not included in this solicitation.

RESPONSE 1 - The gate house is part of the Primary ECP. The paragraph should read as follows:

## 4.14.2 PRIMARY ECP

The Primary ECP shall include an aggregate entrance; a manually-operated sliding steel gate; a gate house; guard shack; canopy; an active vehicle barrier; and passive vehicle barriers placed in serpentine pattern to prevent high speed vehicle entry into compound. Provide a 5 meter wide rejection lane entered between the vehicle inspection stop and the compound entry gates. Refer to Appendix B for related drawings and details.

QUESTION 7 - The Capacity of Fuel Tank for Generator is not specified; please specify the exact size of the Fuel tank.

RESPONSE 2 - Fuel storage for the generator is for 30 days and is defined in paragraph 6.20.4.

QUESTION 8: Is there any requirement for the lean concrete below the foundation's RCC Concrete? (as its not shown on any of the drawings)

RESPONSE: No, there is no requirement for lean concrete below the foundation.

QUESTION 9 - As per our previous experience with USACE, the excavation for foundations are normally extended 300 ~ 400 mm beyond the depth shown on the drawing. This extra depth is then backfilled with "suitable material" (normally granular material), laid in layers and compacted to a specified compaction level. Will the same practice be adopted for subject solicitation number????

Response: Geotechnical data is not available for the sites that will fall under this MATOC contract. The Contractor is responsible for conducting the geotechnical investigation, testing, and making all foundation recommendations. Foundations must be placed on suitable compacted ground a minimum of 800 mm below grade or below the frost line, whichever is greater. If the Geotechnical report finds that the soils are unsatisfactory, then over excavation may be required. It is not possible to determine at this time how many or what projects may require over excavation. It is also not possible to determine to what depth over excavation would need to be preformed, until the site specific geotechnical report is completed.